

MAYOR

James Dodge

VILLAGE CLERK

Mary Ryan Norwell

14700 S. Ravinia Avenue
Orland Park, IL 60462
(708)403-6100
orlandpark.org

**TRUSTEES**

William R. Healy

Cynthia Nelson Katsenes

Michael R. Milani

Dina M. Lawrence

John Lawler

Joanna M. Liotine Leafblad

October 31, 2025

**ADDENDUM #9 – Nicor’s Response to Question 10: Construction Access Points, Utility Crossings
ITB #25-049 - Tinley Creek Bank Stabilization, Construction**

Addendum #5 (10/22/2025)

Q: There are several construction access points shown. Some of those locations show utilities. Do we have to have protection pads over the lines, or will we be able to run loaded semis over them? If we have to have construction access pads, will you make an allowance as this will be difficult to determine the cost at bid time?

A1: We are coordinating with Nicor to get an answer to this question for exact requirements they may have and will be sent in a future addendum or shared with the selected contractor.

Addendum #9 (10/31/2025)

A2: Nicor Engineering has confirmed that no additional protection measures will be needed on this project, but it is required that when work is being completed in close proximity to Nicor’s existing facilities, Nicor Watch & Protect be contacted.

Please see the guidance and contact information for Nicor Watch & Protect below:

- When working within 25’ of the pipeline, a representative from Nicor Watch and Protect Department must be present:
- A valid JULIE must be called prior to working within 25' of the pipeline.
- Please coordinate all field activities with Hensley Gooden (hgooden@southernco.com) at 630-514-7737 or William Bell (wbell@southernco.com) at 312-965-5068.